

**2018 Jefferson Street Water
CITY OF LANDER**

ADDENDUM NO. 1

Contract Documents, Specifications and Drawings for “ 2018 Jefferson Street Water” for the City of Lander.

Owner: City of Lander
240 Lincoln Street
Lander, WY 82520

Date Issued: April 16, 2018

Bid Opening: **Tuesday, April 17, 2018 at 2:00 p.m.** (Unchanged)
City Hall

A. SCOPE

This Addendum No. 1 consists of pages AD1-1 through AD1-2. Addendum No. 1 addresses the following additions, changes and clarifications to the Contract Documents and Specifications, and to the Drawings for the above referenced project.

B. MODIFICATIONS TO THE CONTRACT DOCUMENTS and SPECIFICATIONS

SECTION 00 73 00 – Supplementary Conditions

Pages 00 73 00-2 through 3

Make the following changes to the insurance requirements:

SC 6.03 K 3 Change the Combined Single Limit on Automobile Liability to \$1,000,000.

SC 6.03 K 4 Change the Excess or Umbrella Liability to \$2,000,000

SC-6.03 K 5 Delete section in its entirety.

SC-6.03 K 6 Add WYDOT and Gores and Associates to additional insureds.

SC-6.03 K 7 Delete section in its entirety.

SC-6.04 – Add the following language to the end of the paragraph “Contractor shall not provide an Owner’s Protective policy for the project.”

SC 6.05 – Delete SC 6.05 in its entirety and replace with “Delete Paragraphs 6.05 in its entirety.”

C. MODIFICATIONS and CLARIFICATIONS TO DRAWINGS

Add the following Construction Notes to Sheet 4

15. Swivel Tees are acceptable instead of using Foster Adapters.

16. All valves shall be epoxy coated.

17. Cathodic protection is not required for the project.

- 18. The invert of the 8-inch sewer line on Riverview Drive where the proposed water line crosses it on Jefferson Street is calculated to be at elevation 5328.0. The elevation would make the line approximately 8' deep to the bottom of pipe. It is anticipated that the proposed water line shall go above the crossing.
- 19. Fire hydrant laterals can be either ductile iron or pvc and restrained per the specifications.

D. ACKNOWLEDGMENT BY BIDDER

This Addendum No. 1 to the above project shall become a part of the Specifications and Contract Documents, and shall be binding in all respects. Information contained in this Addendum No. 1 shall supersede any information presented in the Contract Documents and Specifications, and as shown on the Drawings.

Attachment to Specifications: The Bidder shall sign and permanently affix this Addendum No. 1 via staples or other means, to the inside front cover of the Contract Documents and Specifications so that it will be turned in with the bid. The Bidder shall also indicate receipt of this Addendum on the Bid Form on page 00 41 00-1 of the Contract Documents and Specifications.


The undersigned Bidder acknowledges receipt of this Addendum No. 1 and incorporation of same into the Contract Documents, Specifications and Drawings.

Received by: _____

Company: _____

Date: _____

Prepared by: _____



Lance R. Hopkin, PE
City Engineer